

Environmental Health & Safety Incident Records Daily Records

<u>Date:</u>	<u>Time:</u>	<u>Building Name:</u>	<u>Incident Type:</u>	<u>Cause</u>	<u>Action:</u>	<u>Officer:</u>	<u>F.D.</u>
11/16/2009 20090888	1733 1802	M VAN RENSSLAER HALL	P - Assist Ill / Injured	Chest Pain	Assisted Bangs Ambulance	Jordan 150	IFD,
11/16/2009 20090889	1922 1940	AREA-WILLARD STRAIGHT	P - Assist Ill / Injured	Illness	Assisted Bangs Ambulance	Jordan 150	IFD,
11/16/2009 20090890	2344 2359	WAIT AVENUE 302 Alarm Panel	T - Alarm	Device Found, Undetermined Cause	System Reset	Walters 189	
11/17/2009 20090891	0928 0937	ALICE H. COOK HOUSE (04) Floor by room 421	f - Alarm	Accidental, Burned Food	Device Replaced	Gingras 112	IFD,
11/17/2009 20090892	1415 1427	MYRON TAYLOR HALL (02) Floor	p - Elevator	Malfunction,	Passengers Released prior to arrival	Gingras 112	
11/17/2009 20090893	1530 1548	SAGE AVE Near Sage Hall	P - Gasoline/Diesel Fuel Leak	Vehicle Leaked Gasoline	Cleaned Up/Disposed Of	Jordan 150	
11/17/2009 20090894	1551 1603	SCHUYLER HOUSE, SECTION 1 (04) West Top Of Stairwell	F - Alarm	Accidental, Dust	Device Replaced	Jordan 150	IFD,
11/17/2009 20090895	1616 1801	MAPLEWOOD PARK Apartment "F" Complex	T - Alarm	Malfunction, Battery Fault	System Reset Prior to Arrival	Jordan 150	
11/17/2009 20090896	2050 2102	MAPLEWOOD PARK Apartment "F" Complex	T - Alarm	Malfunction, Battery Fault	System Reset Prior to Arrival	Jordan 150	
11/17/2009 20090899	2124 2124	SCHURMAN HALL Room S1023	T - Alarm	Malfunction	System Reset Prior to Arrival	Jordan 150	
11/18/2009 20090897	0043 0102	MARY DONLON HALL Penthouse	T - Alarm	Accidental, Dust	Device Replaced	Down 180	

Environmental Health & Safety Incident Records Daily Records

<u>Date:</u>	<u>Time:</u>	<u>Building Name:</u>	<u>Incident Type:</u>	<u>Cause</u>	<u>Action:</u>	<u>Officer:</u>	<u>F.D.</u>
11/18/2009 20090898	0447 0603	PLEASANT GROVE ROAD <small>At Credit Farm Dr</small>	P - Motor Vehicle/Bicycle Accident	Motor Vehicle Accident	Assisted Fire Department	Down 180	CHF
11/18/2009 20090900	0938 0954	CENTRAL HEATING PLANT <small>(01) Floor fire pump</small>	T - Alarm	Device Found, Undetermined Cause	System Reset Prior to Arrival	Walters 189	
11/18/2009 20090901	1015 1026	NORTH CAMPUS TOWNHOUSE C <small>Apartment C2</small>	P - Safety Complaint	Device hanging by wires	Device Replaced	Walters 189	
11/18/2009 20090902	1232 1249	ROBERT PURCELL COMMUNITY CTR	241 - Assist Ill / Injured	Knee / Leg Pain	Assisted Bangs Ambulance	Jordan 150	
11/18/2009 20090903	1929 1940	OLIN HALL <small>(02) Floor by room 201</small>	f - Alarm	Accidental, Dust	Device Replaced	Gingras 112	IFD,
11/18/2009 20090904	2056 2130	SCHURMAN HALL <small>Alarm Panel</small>	t - Alarm	Malfunction, Ground Fault	EMCS Notified	Gingras 112	
11/19/2009 20090905	0502 0526	COURT RESIDENCE HALL	P - Assist Ill / Injured	Altered Mental State	Assisted Bangs Ambulance	Down 180	
11/19/2009 20090906	1427 1445	MORRILL HALL	P - Assist Ill / Injured	Illness	Assisted Bangs Ambulance	DeMarco 111	
11/19/2009 20090907	1445 1503	EAST AVENUE	P - Assist Ill / Injured	Patient struck by metal shelf - laceration	Assisted Bangs Ambulance	DeMarco 111	IFD,
11/19/2009 20090908	1527 1541	SIBLEY HALL	p - Assist Ill / Injured	Illness	Investigated	Gingras 112	
11/19/2009 20090909	1629 1647	BIOTECHNOLOGY <small>(03) North</small>	p - Elevator	Malfunction,	Passengers Released	Gingras 112	

Environmental Health & Safety Incident Records Daily Records

<u>Date:</u>	<u>Time:</u>	<u>Building Name:</u>	<u>Incident Type:</u>	<u>Cause</u>	<u>Action:</u>	<u>Officer:</u>	<u>F.D.</u>
11/19/2009 20090910	1636 1658	COURT RESIDENCE HALL <small>(03) Floor by room 304B</small>	t - Alarm	Malfunction,	System Reset	Gingras 112	
11/19/2009 20090911	1742 1747	HASBROUCK APARTMENTS <small>Apartment building 15</small>	t - Alarm	Malfunction,	System Reset Prior to Arrival	Gingras 112	
11/19/2009 20090912	1756 1824	HASBROUCK APARTMENTS <small>Apartment building 15</small>	t - Alarm	Malfunction,	System Reset Prior to Arrival	Gingras 112	
11/19/2009 20090913	2140 2150	NORTH CAMPUS TOWNHOUSE F	p - Assist Ill / Injured	Illness	Investigated	Gingras 112	CHF
11/20/2009 20090914	0211 0248	AREA-SERVICE BUILDING	DO - Assist Ill / Injured	Altered Mental State	Assisted Bangs Ambulance	Down 180	IFD,
11/20/2009 20090915	0313 0330	P-B LOT	P - Assist Ill / Injured	Illness	Assisted Bangs Ambulance	Down 180	
11/20/2009 20090916	0455 0518	HANS BETHE HOUSE	P - Activated Detector	Accidental, Dust	Device Replaced	Down 180	
11/20/2009 20090917	0620 0646	UPSON HALL <small>(01) Floor near 101</small>	P - Chemical Incident	pressure pump gasket leak	EMCS Notified	Down 180	
11/20/2009 20090918	0630 0640	FRANK H T RHODES HALL <small>Room 302</small>	DO - Smoke Odor	Malfunction, Light ballast	Investigated	Down 180	
11/20/2009 20090919	0933 0951	NORTH CAMPUS TOWNHOUSE F	P - Assist Ill / Injured	Illness	Assisted Bangs Ambulance	DeMarco 111	CHF
11/21/2009 20090920	0215 0235	HANS BETHE HOUSE	P - Assist Ill / Injured	Altered Mental State	Assisted Bangs Ambulance	Down 180	IFD,

Environmental Health & Safety Incident Records Daily Records

<u>Date:</u>	<u>Time:</u>	<u>Building Name:</u>	<u>Incident Type:</u>	<u>Cause</u>	<u>Action:</u>	<u>Officer:</u>	<u>F.D.</u>
11/21/2009 20090921	1403 1421	MCGRAW PL 122, HILLCREST SAE <small>Alarm Panel</small>	F - Alarm	Accidental, Water in Device	System Reset	DeMarco 111	IFD,
11/21/2009 20090922	1849 1912	BARTELS HALL	p - Assist Ill / Injured	Sports Injury	Assisted Bangs Ambulance	Gingras 112	IFD,
11/21/2009 20090923	1928 1947	LYNAH RINK	r - Assist Ill / Injured	Sports Injury	Assisted Bangs Ambulance	Gingras 112	IFD,
11/21/2009 20090924	2057 2112	REIS TENNIS CENTER <small>(01) Floor</small>	t - Alarm	Accidental, Dust	Device Replaced	Gingras 112	
11/21/2009 20090925	2135 2211	MARY DONLON HALL <small>(04) Floor section C</small>	f - Alarm	Accidental, Dust	Device Serviced/Replaced	Gingras 112	IFD,
11/21/2009 20090926	2216 2250	COURT RESIDENCE HALL	p - Assist Ill / Injured	Altered Mental State	Assisted Bangs Ambulance	Gingras 112	
11/22/2009 20090927	0154 0222	MARY DONLON HALL	P - Assist Ill / Injured	Ankle Injury	Splinted Ankle & RMA	Maas 107	
11/22/2009 20090928	1402 1422	MEWS RESIDENCE HALL <small>(01) Floor, East Telecom Room</small>	P - Audible/Visible Alarm	Alarm on A/C unit was sounding	Investigated	Jelliff 188	
11/22/2009 20090930	1644 1517	BEEBE HALL <small>Room 423a</small>	P - Activated Detector	Accidental, Dust	Device Replaced	MacCheyne 103	