

Environmental Health & Safety Incident Records Daily Records

<u>Date:</u>	<u>Time:</u>	<u>Building Name:</u>	<u>Incident Type:</u>	<u>Cause</u>	<u>Action:</u>	<u>Officer:</u>	<u>F.D.</u>
11/9/2009 20090834	0219 0235	MYRON TAYLOR HALL (03) West Stairs	F - Alarm	Malfunction, Flow Switch	System Reset	Walters 189	IFD,
11/9/2009 20090835	0641 0655	OLIN HALL (02) East	F - Alarm	Accidental, Dust	Device Serviced/Replaced	Walters 189	IFD,
11/9/2009 20090838	0756 0915	BOYCE THOMPSON INSTITUTE Room 418	P - Chemical Incident	Accidental,	Cleaned Up/Disposed Of	MacCheyne 103	
11/9/2009 20090837	0805 0840	STATLER HALL & AUDITORIUM Fire Pump	P - Safety Complaint	Accidental, Power Outage	System Reset	Jelliff 188	
11/9/2009 20090836	0900 0910	BARTELS HALL Alarm Panel	T - Alarm	Undetermined	System Reset Prior to Arrival	Jelliff 188	
11/9/2009 20090840	1233 1314	SOUTH AVENUE 6,DELTA UPSILON Basement Valve Room	T - Alarm,	Low Temperature Thermostat Set Too High	Panel Silenced	Jelliff 188	
11/9/2009 20090839	1315 1352	BROWN RD 95, #6 LANGMUIR LAB (01) Floor	F - Alarm	Accidental, Water Surge	System Reset	Jelliff 188	LFD,
11/9/2009 20090841	1739 1748	MYRON TAYLOR JANE FOSTER ADD	P - Assist Ill / Injured	Patient Fell	Assisted Bangs Ambulance	Jordan 150	
11/9/2009 20090842	1748 1806	MYRON TAYLOR JANE FOSTER ADD (01) Floor Elevator Lobby	F - Alarm	Accidental, Dust	Device Replaced	Jordan 150	IFD,
11/9/2009 20090843	1818 1824	HASBROUCK APARTMENTS Apartment 1204	P - Activated Detector	Accidental, Burned Food	Investigated	Jordan 150	
11/10/2009 20090844	0919 0949	MANN LIBRARY (01) Floor	T - Alarm	Malfunction, Defective Device	Device Replaced	DeMarco 111	

Environmental Health & Safety Incident Records Daily Records

<u>Date:</u>	<u>Time:</u>	<u>Building Name:</u>	<u>Incident Type:</u>	<u>Cause</u>	<u>Action:</u>	<u>Officer:</u>	<u>F.D.</u>
11/10/2009 20090845	1344 1415	HELEN NEWMAN HALL	p - Assist Ill / Injured	Sports Injury	Assisted Bangs Ambulance	Gingras 112	
11/10/2009 20090846	1431 1448	MANN LIBRARY	r - Assist Ill / Injured	Illness	Assisted Bangs Ambulance	Gingras 112	
11/10/2009 20090847	1638 1708	MALOTT HALL <small>(04) near room 402</small>	T - Alarm	Accidental, Dust	Device Replaced	Jordan 150	
11/10/2009 20090848	1957 2027	JOHN T OXLEY EQUESTRIAN CENTER	P - Assist Ill / Injured	Patient Fell From Horse	Assisted Bangs Ambulance	Jordan 150	IFD
11/11/2009 20090849	0807 0833	STATLER HALL & AUDITORIUM	P - Assist Ill / Injured	Illness	Assisted Bangs Ambulance	Walters 189	
11/11/2009 20090850	1002 1020	AREA-626 THURSTON AVE	R - Assist Ill / Injured	Patient Fell	Assisted Bangs Ambulance	DeMarco 111	
11/11/2009 20090851	1011 1039	COURT RESIDENCE HALL	P - Assist Ill / Injured	Illness	Assisted Bangs Ambulance	Jordan 150	
11/11/2009 20090852	1132 1150	CLARK HALL <small>Basement</small>	F - Alarm	Accidental, Water Surge	Zone Isolated/Device Disabled	DeMarco 111	IFD,
11/11/2009 20090853	1659 1720	MYRON TAYLOR HALL <small>(03) Floor</small>	F - Alarm	Accidental, Water Surge	System Reset	Jelliff 188	IFD,
11/11/2009 20090856	1702 1721	FRANK H T RHODES HALL <small>Alarm Panel</small>	T - Alarm	Undetermined	System Reset Prior to Arrival	Jelliff 188	
11/11/2009 20090854	1820 1902	MYRON TAYLOR HALL <small>(03) Floor, Moot Courtroom</small>	F - Alarm	Accidental, Dust	Device Replaced	Jelliff 188	IFD,

Environmental Health & Safety Incident Records Daily Records

<u>Date:</u>	<u>Time:</u>	<u>Building Name:</u>	<u>Incident Type:</u>	<u>Cause</u>	<u>Action:</u>	<u>Officer:</u>	<u>F.D.</u>
11/11/2009 20090855	2006 2021	MARY DONLON HALL Room 633	P - Activated Detector	Accidental, Dust	Device Replaced	Jelliff 188	
11/12/2009 20090857	0451 0515	SCHURMAN HALL Alarm Panel	T - Alarm	Malfunction, missing pull box	Investigated	Down 180	
11/12/2009 20090859	0927 0959	STATLER HALL & AUDITORIUM (02) Floor Beverage Mgmt. Area	T - Alarm	Device Found, Undetermined Cause	System Reset	Walters 189	
11/12/2009 20090858	0935 0953	BIG RED BARN Basement	P - Reported Odor	Undetermined	Investigated	DeMarco 111	
11/12/2009 20090861	1040 1102	BRADFIELD HALL (01) East Elevator	P - Elevator	Accidental, Workmen	Passengers Released	Walters 189	
11/12/2009 20090862	1105 1116	TOWER ROAD North near Plant Science LD	DO - Safety Complaint	Undetermined	Hole filled	Walters 189	
11/12/2009 20090860	1200 1118	EAST HILL OFFICE BUILDING Alarm Panel	T - Alarm	Undetermined	System Reset Prior to Arrival	DeMarco 111	
11/12/2009 20090863	1433 1450	HELEN NEWMAN HALL	P - Assist Ill / Injured	Illness	Assisted Bangs Ambulance	Walters 189	
11/12/2009 20090864	1450 1524	MANN LIBRARY (01) Floor	T - Alarm	Accidental, Dust	Zone Isolated/Device Disabled	DeMarco 111	
11/12/2009 20090865	1737 1757	HANS BETHE HOUSE	P - Assist Ill / Injured	Illness	Assisted Bangs Ambulance	Jelliff 188	IFD,
11/12/2009 20090866	2245 2309	ALICE H. COOK HOUSE (01) Floor	P - Smoke Condition	Malfunction, Water In Electric Socket	Shut off breaker to outlet	Jelliff 188	IFD,

Environmental Health & Safety Incident Records Daily Records

<u>Date:</u>	<u>Time:</u>	<u>Building Name:</u>	<u>Incident Type:</u>	<u>Cause</u>	<u>Action:</u>	<u>Officer:</u>	<u>F.D.</u>
11/12/2009 20090867	2250 2332	THURSTON AVENUE 534, ZETA PSI <small>(02) Floor Hallway</small>	F - Alarm	Malicious	Devices Replaced	Jelliff 188	IFD,
11/13/2009 20090868	0155 0212	THURSTON AVENUE 534, ZETA PSI <small>(02) Floor Near 209</small>	F - Alarm	Malicious discharge of extinguisher	Device Replaced	Down 180	IFD,
11/13/2009 20090869	0212 0240	NORTH CAMPUS LOW RISE #7	P - Assist Ill / Injured	Altered Mental State	Assisted Bangs Ambulance	Down 180	CHF
11/13/2009 20090870	0411 0427	STATLER HALL & AUDITORIUM <small>Alarm Panel</small>	T - Alarm	Accidental, Workmen	Investigated	Down 180	
11/13/2009 20090871	0550 0615	MANN LIBRARY <small>(01) Floor near 108</small>	T - Alarm	Accidental, Dust	Device Replaced	Down 180	
11/14/2009 20090872	0135 0149	THURSTON COURT APARTMENTS	DO - Assist Ill / Injured	Altered Mental State	Assisted Bangs Ambulance	Down 180	IFD,
11/14/2009 20090873	0156 0220	AREA-626 THURSTON AVE	DO - Assist Ill / Injured	Altered Mental State	Assisted Bangs Ambulance	Down 180	IFD,
11/14/2009 20090874	1325 1350	HANS BETHE HOUSE <small>Room 301A</small>	P - Activated Detector	Accidental, Dust	Device Replaced	DeMarco 111	
11/14/2009 20090875	1624 1649	STATLER HOTEL	p - Assist Ill / Injured	Illness	Assisted Bangs Ambulance	Gingras 112	IFD,
11/14/2009 20090876	1747 1831	GRUMMAN SQUASH COURTS <small>Basement baseball locker room</small>	p - Report of Fire	Fire	Investigated	Gingras 112	IFD,
11/14/2009 20090878	2036 2101	SCHURMAN HALL <small>Room S1023 kitchen first floor</small>	t - Alarm	Malfunction,	Zone Isolated/Device Disabled	Gingras 112	

Environmental Health & Safety Incident Records Daily Records

<u>Date:</u>	<u>Time:</u>	<u>Building Name:</u>	<u>Incident Type:</u>	<u>Cause</u>	<u>Action:</u>	<u>Officer:</u>	<u>F.D.</u>
11/14/2009 20090877	2059 2110	ALICE H. COOK HOUSE <small>(04) Floor hall by room 421</small>	f - Alarm	Accidental, Burned Food	System Reset	Gingras 112	IFD,
11/14/2009 20090879	2326 2348	UNIVERSITY AVENUE	R - Assist Ill / Injured	Altered Mental State	Assisted Bangs Ambulance	Walters 189	IFD,
11/15/2009 20090880	0005 0030	MCGRAW PL 122, HILLCREST SAE <small>North side woods near building</small>	DO - Brush/Mulch Fire	Fire	Assisted IFD	Walters 189	IFD,
11/15/2009 20090881	0300 0320	MARY DONLON HALL	P - Assist Ill / Injured	Altered Mental State	Assisted Bangs Ambulance	Walters 189	IFD,
11/15/2009 20090882	0424 0440	WILLARD STRAIGHT HALL <small>(01) Floor Ceramics Room</small>	P - Safety Complaint	Kiln accidentally left on	Investigated	Walters 189	
11/15/2009 20090883	0505 0520	RISLEY, PRUDENCE RESD. COLLEGE	P - Assist Ill / Injured	Altered Mental State	Assisted Bangs Ambulance	Walters 189	
11/15/2009 20090884	0819 0911	STATLER HOTEL	P - Assist Ill / Injured	Patient Lost Consciousness	Assisted Bangs Ambulance	Jelliff 188	IFD,
11/15/2009 20090885	1751 1803	CLARA DICKSON HALL <small>(03) near room 3535</small>	F - Alarm	Accidental, Burned Food	Device Replaced	Jordan 150	IFD,
11/15/2009 20090886	1835 1905	GEORGE JAMESON HALL	P - Assist Ill / Injured	Difficulty Breathing	Assisted Bangs Ambulance	Jordan 150	IFD
11/15/2009 20090887	2048 2112	NORTH CAMPUS HIGH RISE #5	P - Assist Ill / Injured	Difficulty Breathing	Assisted Bangs Ambulance	Jordan 150	IFD